

# 1 UK shallow ground temperatures for ground coupled heat exchangers

2 Jon Busby

3 British Geological Survey, Keyworth, Nottingham, NG12 5GG, UK.

4 Email [jpbu@bgs.ac.uk](mailto:jpbu@bgs.ac.uk)

## 5 Abstract

6 Accurate estimations of shallow ground temperatures are required when sizing the horizontal  
7 closed loops and air supply culverts of ground coupled heating and cooling systems. These  
8 collector loops and culverts are within the zone affected by the seasonal swing in  
9 temperatures. Soil temperatures from 106 Met Office weather stations, located across the UK,  
10 have been analysed from which mean annual, seasonal minimum and maximum and daily  
11 minimum and maximum temperatures have been calculated. Mean annual temperatures at 1  
12 m depth, reduced to sea level, range from 12.7 °C in southern England to 8.8 °C in northern  
13 Scotland, with corresponding seasonal ranges in temperature of 10.3 °C and 7.9 °C  
14 respectively. An average Urban Heat Island (UHI) effect at 1 m depth of 0.55 °C has been  
15 observed at localities adjacent to urban green spaces, from which it can be assumed that the  
16 UHI effect will be greater in densely developed city and town centres. A linear relation has  
17 been derived for the mean annual temperature at any non-urban UK locality, at 1 m depth.  
18 The seasonal temperature cycle has been extrapolated accurately to several metres depth with  
19 site specific thermal properties derived from the soil temperature measurements.

20 When designing closed-loop horizontal and vertical ground heat exchangers the temperature  
21 of the ground is a crucial parameter for correctly sizing the loops, whether the system is to be  
22 used for heating and/or cooling. Accurate ground temperatures are also required for passive  
23 heating and cooling systems, which temper ventilation air by introducing it through a large,  
24 buried air supply culvert, and this requires accurate knowledge of the seasonal temperature  
25 variations in the top 5 m of the ground (Orme & Isanska-Cwiek 2012). The temperature in  
26 the ground at around 15 m depth is equal to the mean annual air temperature (Rybach &  
27 Sanner 2000). At sea level for mainland UK, mean annual air temperature varies from north  
28 to south from about 8 to 12 °C (Perry & Hollis 2005). Air temperatures are mainly affected  
29 by position and elevation. The decrease of air temperature with increasing altitude is given by  
30 the Environmental Lapse Rate which has an average value of 0.65 °C per 100 m (ICAO  
31 1993). Temperatures in the ground beneath the zone affected by seasonal fluctuations (i.e., >  
32 15 m depth) will increase with depth depending on the local heat flow and the thermal  
33 conductivity of the ground. The average increase, referred to as the geothermal gradient, for  
34 the UK is 2.6 °C per 100 m. Assuming that heat transfer is only by conduction, Busby *et al.*  
35 (2009) generated temperatures for Great Britain at 100 m depth that showed a range of 4 to  
36 17 °C. Within hydraulically transmissive rocks, heat can also be transferred by advection.  
37 Headon *et al.* (2009) report temperatures ranging from 11-15 °C at constant depths below  
38 ground level of 80 and 100 m within the Chalk aquifer below London. The higher  
39 temperatures in the SW of their study area are compatible with the geothermal gradient, but  
40 the lower temperatures in the east were speculatively attributed to recharge of cooler water.  
41 Pike *et al.* (2011) report a more extensive set of temperature measurements in the Chalk  
42 aquifer of the western London Basin syncline. At 100 m below ground level, temperatures  
43 varied from 9-9.5 °C to 14.5-15 °C. This range in temperatures was partly attributed to  
44 ground surface elevation, but the higher temperatures were not fully explained; one  
45 possibility being that the Tertiary sequence overlying the Chalk may have a lower bulk  
46 thermal conductivity, and hence insulating effect, than would be expected.

47 Horizontal ground loop collectors are buried either in a trench of sufficient width to allow the  
48 pipe to be looped horizontally along its base or looped vertically in a slit trench. Suggested  
49 depths of the trenches vary, for instance, Banks (2008) indicates 1.2-2 m, the IGSHPA (1996)  
50 rule of thumb is 1.2-1.8 m and VDI (2001) suggest 1.2-1.5 m. The trenches are within ground  
51 that is affected by the daily and seasonal temperature fluctuations, although the daily  
52 fluctuation only penetrates a few tens of centimetres (Banks 2008). It is a requirement (MIS  
53 3005 2013) for the swing of ground temperatures through the year to be incorporated in  
54 ground source heat pump design so that base load and peak load requirements are met. The  
55 amplitude of the seasonal temperature swing decreases, and is offset in time, with depth  
56 (Banks 2008).

57 Maps of average soil temperatures at 30 cm depth are available from the Met Office based on  
58 monthly, seasonal or annual averages (<http://www.metoffice.gov.uk/public/weather/climate/>).  
59 There are also online agricultural services that will generate a soil temperature at 10 cm depth  
60 for a UK postcode based on the average of the 5 closest Met Office weather stations (e.g.  
61 <https://www.kws-uk.com/go/id/fnbz>) or apps that will give a monthly or annual average soil  
62 temperature (e.g. <http://www.bgs.ac.uk/mySoil/>). However, none of these services give  
63 temperatures for 100 cm depth, the average depth of a horizontal ground loop collector.

64 It has been widely reported that urban areas, especially large towns and cities, have raised  
65 mean annual air temperatures when compared to rural areas (e.g., Pollack *et al.* 1998; Magee  
66 *et al.* 1999; Perrier *et al.* 2005; Taniguchi *et al.* 2007). This is due to a variety of factors  
67 including, large tarmac/paved areas that preferentially absorb solar energy compared to  
68 vegetation, re-radiation of thermal energy at night from buildings warmed during the day and  
69 heat leakage from poorly insulated buildings (Linacre & Geerts 1997). Higher mean air  
70 temperatures will also affect sub-surface temperatures that will also be enhanced by heat  
71 leakage from the floors and basements of buildings (Ferguson & Woodbury 2004; Ferguson  
72 & Woodbury 2007) and heat discharged from underground services, especially water and  
73 sewage pipes (Banks *et al.* 2009). This thermal anomaly is known as the urban heat island  
74 (UHI) effect (Oke 1973). It represents an increased sub-surface thermal resource that can be  
75 exploited by thermal ground coupling technology (Zhu *et al.* 2010), but can create problems  
76 for those designing ground coupled passive heating and cooling systems where accurate  
77 ground temperatures are required.

78 Most urban sub-surface temperature measurements have been made in boreholes. Banks *et al.*  
79 (2009) report an increase of around 2-3 °C at 20 m depth in two closed loop boreholes in  
80 Gateshead, Tyne and Wear, UK. Ferguson & Woodbury (2007) measured temperatures in 40  
81 water wells in Winnipeg, Manitoba, Canada, from which they constructed a groundwater  
82 contour map at 20 m depth. This showed a general increase of 2-3 °C in the city centre  
83 compared to agricultural areas, but subsurface temperatures beneath green spaces in the city  
84 were lower than beneath business districts in the city centre. Menberg *et al.* (2013) examined  
85 shallow groundwater temperatures under six German cities and found regional differences in  
86 elevated temperatures between urban and rural areas of 3-7 °C. In Berlin, Munich and  
87 Cologne, the highest temperatures were close to or in the city centre, whilst in Karlsruhe and  
88 Darmstadt they were found in industrial areas and close to landfill sites. In three investigated  
89 cities in Finland, Arola & Korkka-Niemi (2014) found the average groundwater  
90 temperatures, below the seasonal fluctuation zone, were 1.3–2.0 °C higher in the urban area  
91 and 3.0–4.0 °C higher in the city centre than in the rural area around them.

92 There is very little in the literature on the UHI effect in the top 5 m of the ground. At these  
93 shallow depths, temperatures are affected by the seasonal swing in air temperature. The  
94 location of the site (i.e. proximity to green space) is likely to have an increased influence

95 compared to temperatures at greater depths and the UHI effect may itself have a seasonal  
96 component.

97 This Technical Note presents soil temperature data from Met Office stations across the UK to  
98 a depth of 100 cm. The data is intended to assist those who require accurate shallow  
99 temperature data. Predictive trends are identified and some initial indications of the UHI  
100 effect in the top 5 m of the ground are investigated.

## 101 **Methodology**

102 Soil temperature data are collected and archived by the UK Met Office at several hundred  
103 weather stations and are made available for academic purposes via the British Atmospheric  
104 Data Centre (<http://badc.nerc.ac.uk/home>). The data are recorded at 09:00 each day at depths  
105 of 5, 10, 20, 30, 50 and 100 cm, although not all depths are covered at each station and some  
106 temperature depth records may be discontinuous. The data are recorded to the nearest 0.1 °C.  
107 In general, these sites are on level ground with no trees, buildings or steep ground nearby  
108 (Met Office 2010). A typical soil temperature record for 5 years from the Met Office weather  
109 station at Eastbourne with daily temperature readings at 30 cm depth (black lines) and 100  
110 cm depth (grey lines) is shown in Figure 1. There is considerable daily temperature  
111 fluctuation and hence a function of the form;

$$112 \quad Y = a_0 + a_1 \cos(wX) + b_1 \sin(wX) \quad (1)$$

113 has been fitted to the data (see the bold lines in Figure 1) in order to identify seasonal trends.

114 From these daily data the following temperatures are derived:

115 Mean annual – The mean temperature over several continuous full years between  
116 2000-2010 at depths of 30, 50 and 100 cm.

117 Seasonal minimum – The minimum temperature of the fitted function at depths of 30, 50  
118 and 100 cm.

119 Seasonal maximum – The maximum temperature of the fitted function at depths of 30, 50  
120 and 100 cm.

121 Daily minimum – The minimum daily temperature recorded over the period from  
122 which the mean was calculated, at depths of 30, 50 and 100 cm.

123 Daily maximum – The maximum daily temperature recorded over the period from  
124 which the mean was calculated, at depths of 30, 50 and 100 cm.

125 If heat transfer into the ground is solely by conduction then the mean temperatures at two  
126 depths should be equal (since the contribution from the geothermal gradient is negligible at  
127 0.02-0.04 °C/m). Differences indicate the influence from other heat transfer processes such as  
128 evapotranspiration and advection. If taken over several full years, the mean should not be too  
129 affected by exceptionally cold or warm years. The seasonal minimum and maximum  
130 temperatures represent average cold and warm conditions that can assist in designing a  
131 ground loop for peak load conditions. Extreme temperatures are given by the daily minimum  
132 and maximum temperatures and these will be more dependent on the time period considered.  
133 Extreme temperatures in the UK usually only last for a few days, although in exceptional  
134 conditions they can last for weeks or even months. These daily extremes may need to be  
135 considered when designing for peak load conditions for a vertically looped horizontal  
136 collector, but should have dissipated to low levels at the depth of a horizontally coiled  
137 collector. As discussed above, the seasonal temperature fluctuation in the ground decreases in  
138 amplitude and increases in phase shift (time offset) with depth. This can be seen clearly in the  
139 fitted curves in Figure 1. For two vertically separated soil temperature measurements

140 resulting from a periodic heating cycle (e.g. the yearly cycle), the amplitude and phase  
141 changes can be used to derive the thermal diffusivity of the soil (Kappelmeyer & Haenel  
142 1974; Adams *et al.* 1976; Horton *et al.* 1983). This is not included here, but a full account is  
143 given in Busby (2015).

144 Soil temperature data from 106 UK Met Office weather stations have been analysed and their  
145 distribution is shown in Figure 2. Geographical information on these 106 stations is presented  
146 in Table A1 in the Appendix. They cover the full geographical extent of the UK and include  
147 coastal and urban settings. Datasets for the period 2000-2010 have been analysed with an  
148 emphasis on temperatures from 100 cm depth (the average depth of a horizontal loop trench),  
149 although data are also presented from depths of 30 and 50 cm. Only continuous yearly  
150 sequences were used to determine the derived temperatures.

## 151 **Results**

152 Tabulated results for each Met Office weather station are presented for England, Scotland,  
153 Wales and Northern Ireland in Tables A2-A5 in the appendix. In England, mean temperatures  
154 at 100 cm depth decrease from around 12 °C in the south to 10 °C in the north with a  
155 minimum of 9 °C at Shap and a maximum of 13 °C at St James' Park, London. Although  
156 Shap is at an altitude of 255 m, Buxton is higher at 307 m, but the corresponding temperature  
157 is 9.8°C and is due to the urbanised setting at Buxton and the exposed location at Shap. The  
158 lowest seasonal minimum at 100 cm depth of 3.8 °C occurs at Shap and the largest maximum  
159 of 18.6°C occurs at both Littlehampton and St James' Park (both urban settings). A seasonal  
160 maximum of 18.5 °C occurs at Westleton, a non-urban setting on the East Anglian coast. The  
161 seasonal minimums at 30 cm depth occur between 24<sup>th</sup> January-3<sup>rd</sup> February and the  
162 maximums between 25<sup>th</sup> July-4<sup>th</sup> August. At 100 cm depth, these minimum and maximum  
163 temperatures are delayed to 30<sup>th</sup> January-22<sup>nd</sup> February and 31<sup>st</sup> July-22<sup>nd</sup> August,  
164 respectively. The daily minimum at 100 cm depth is 1.5 °C at Warcop Range, 19 km from  
165 Shap and the maximum is 21.6 °C at both St James' Park and Oxford (both urban settings).

166 For Scotland, the range in mean temperatures at 100 cm depth is from around 10 °C in the  
167 south to 9°C in the north with a minimum of 8.2°C at Braemar (at an altitude of 339 m) and a  
168 maximum of 11.1 °C at Paisley (an urban setting). The lowest seasonal minimum at 100 cm  
169 depth of 3°C occurs at Aviemore and the largest maximum of 15.9°C occurs at Paisley. The  
170 seasonal minimums at 30 cm depth occur between 23<sup>rd</sup> January-7<sup>th</sup> February and the  
171 maximums between 24<sup>th</sup> July-7<sup>th</sup> August. At 100 cm depth, these minimum and maximum  
172 temperatures are delayed to 7<sup>th</sup>-23<sup>rd</sup> February and 7<sup>th</sup>-23<sup>rd</sup> August, respectively. The daily  
173 minimum at 100 cm depth is 1.2°C at Aviemore and the maximum is 18 °C at Paisley.

174 There are fewer data for Wales and these show a range in mean temperatures at 100 cm depth  
175 from around 12 °C in the south to 10.5 °C in the north with a minimum of 10.4 °C at  
176 Loggerheads and a maximum of 12.3 °C at Penmaen. The lowest seasonal minimum at 100  
177 cm depth of 5.4 °C occurs at Loggerheads and the largest maximum of 17.6 °C at Penmaen.  
178 The seasonal minimums at 30 cm depth occur between 30<sup>th</sup> January-2<sup>nd</sup> February and the  
179 maximums between 30<sup>th</sup> July-3<sup>rd</sup> August. At 100 cm depth, these minimum and maximum  
180 temperatures are delayed to 11<sup>th</sup>-15<sup>th</sup> February and 12<sup>th</sup>-15<sup>th</sup> August, respectively. The daily  
181 minimum at 100 cm depth is 3.3 °C at Bala and the maximum is 18.9 °C at Penmaen.

182 In Northern Ireland, the minimum mean temperature at 100 cm depth is 10.3 °C at Coleraine  
183 and the maximum is 11.2°C at Annaghmore. The lowest seasonal minimum and largest  
184 maximum at 100 cm depth of 5.7 °C and 16.4 °C, respectively, both occur at St Angelo. The  
185 seasonal minimums and maximums at 100 cm depth occur between 8<sup>th</sup>-19<sup>th</sup> February and 9<sup>th</sup>-

186 20<sup>th</sup> August, respectively. The daily minimum and maximum temperatures at 100 cm depth of  
187 3.8 °C and 17.4 °C, respectively, also both occur at St Angelo.

188 To facilitate comparison, the means and seasonal minimums and maximums at 100 cm depth  
189 have been reduced to sea level with a correction of 0.65 °C per 100 m and are shown in Table  
190 1. Between southern and northern England, the range in mean temperature at 100 cm depth is  
191 2.1 °C, whilst the range in seasonal minimums and maximums is 2.5 °C and 3.1 °C,  
192 respectively. The seasonal range in temperature in southern England is 10.3 °C and in  
193 northern England 10.2 °C. It should be noted that for central England there is no difference in  
194 mean temperatures between east and west, at a corrected to sea level mean value of 11.5 °C.  
195 Between southern and northern Scotland, the corresponding range in sea level corrected mean  
196 temperature is 2.4 °C and the range in seasonal minimums and maximums is 1.7 °C and 4.0  
197 °C, respectively. The seasonal range in temperature in southern Scotland is 9.7 °C and in  
198 northern Scotland 7.9 °C. For Wales, the seasonal range in 100 cm sea level corrected  
199 temperatures is 9.9 °C and for Northern Ireland it is 8.8°C.

200 Some initial indications of the UHI effect have been investigated here by comparing mean  
201 annual temperatures at 100 cm depth between urban locations and, near-by, rural locations.  
202 For the comparisons, temperatures have only been considered over the same time period at  
203 the urban and rural sites and the temperature at the rural location has been corrected for the  
204 elevation difference to the urban site using the Environmental Lapse Rate of 0.65 °C per 100  
205 m. The results are shown in Table 2. For the 10 comparisons considered, there is a  
206 measurable UHI effect at eight of them, with only one site showing a cooler temperature at  
207 the urban location. The maximum UHI effect measured, at Bournemouth, is 1.0 °C, and the  
208 average is 0.55 °C. Met Office weather stations in the urban environment are located on the  
209 edges of green spaces (parks, school playing fields, etc.). Hence, from the evidence cited  
210 above from borehole temperature measurements, it must be assumed that an increased UHI  
211 effect would be expected in the city/town centres. The highest mean annual temperatures  
212 were recorded at St James' Park, a green space in the centre of London. Unfortunately there  
213 is no near-by rural location with temperature data at 100 cm depth, but a comparison can be  
214 made with Aldenham School for 30 cm depth data, resulting in an UHI effect at St James'  
215 Park of 2.2 °C.

216 In Table 3, the same analysis has been applied to the seasonal minimums and maximums with  
217 comparisons between urban and elevation-corrected rural temperatures. For six of the eight  
218 urban locations that showed an UHI effect, the seasonal maximum has a greater UHI effect  
219 than the seasonal minimum, suggesting the effect is more dominant at very shallow depths in  
220 the summer. However, for two of the locations showing an UHI effect (Bradford and Paisley)  
221 this is reversed, as it is also for the two locations (Reading and Cambridge) that did not show  
222 an UHI effect.

## 223 **Discussion**

224 These data provide some insights into the variation of sub-surface temperatures within the top  
225 one metre of the ground, across the UK. Latitude and elevation are the main parameters that  
226 influence temperature. Mean annual temperatures corrected to sea level at 100 cm depth, vary  
227 from 12.7 °C in the south of the UK to 8.8 °C in the north, although higher temperatures can  
228 occur in towns and cities. The range in average seasonal temperatures, i.e. the difference  
229 between warm summer and cold winter, corrected to sea level at 100 cm depth, varies from  
230 10.3 °C in southern England to 7.9 °C in northern Scotland. At a metre depth, for the UK, the  
231 coldest time of year is February and the warmest is August. The Met Office weather stations  
232 are not ideally placed to measure an UHI effect as, within urban areas, they are located  
233 adjacent to green spaces. However, where an effect was recognised, there is an average

234 increase in temperature at 1 metre depth of 0.55 °C. By comparisons with other studies at  
235 greater depth, it must be assumed that the UHI effect will be higher in highly urbanised city  
236 and town centres.

237 For 12 of the stations located across the UK, the mean annual air temperature has been  
238 calculated for the same time periods used to calculate the temperatures at 100 cm depth.  
239 These are shown in Table 4, along with the mean annual temperatures at 100 cm depth. In all  
240 cases the soil temperature is greater than the mean annual air temperature and the range is  
241 0.5-2.0 °C. The average of these 12 comparisons is 0.9 °C, which is in agreement with  
242 accepted practice that mean annual soil temperatures are slightly higher than mean annual air  
243 temperatures (e.g. Banks 2008).

244 In Figure 3 the mean annual temperatures at 100 cm depth for non-urban locations, corrected  
245 to sea level, are plotted against northing. There is a clear, linear trend, but with some scatter  
246 that will be due to other factors that affect the soil temperature, e.g. local topography and  
247 aspect. A linear trend has been fitted to these data that is also shown on Figure 3. From this  
248 fit it is possible to predict the mean temperature for non-urban locations at 100 cm depth as;

$$249 \quad temp = (-3.539 \times 10^{-6} \times northing) + 12.8 - (elevation \times 0.0065) \pm 0.3, \quad (2)$$

250 where *temp* is the predicted temperature in °C, at a location with a *northing* in m, at an  
251 *elevation* above OD in m. The quoted error of ± 0.3 °C is the standard deviation of the linear  
252 fit. For the Met Office stations used here, the maximum deviation between measured and  
253 predicted temperatures is 0.8 °C.

254 With these data it is also possible to generate accurate ground temperatures within the upper  
255 few metres of the ground and this is illustrated with data from the Wallingford Met Office  
256 weather station. The extrapolation of temperature with depth due to periodic surface heating  
257 is given by Beardsmore & Cull (2001) as,

$$258 \quad T_{\theta} = T_0 \exp(-\varepsilon z) \sin(\omega t - \varepsilon z) \quad (3)$$

259 where  $T_{\theta}$  is the departure from a mean value of temperature at a particular depth,  $z$ , and time,  
260  $t$ , due to a heating cycle with amplitude  $T_0$  and frequency  $\omega$ . For Wallingford, the heating  
261 cycle is taken as the seasonally fitted temperature curve at 50 cm depth. The thermal  
262 properties of the medium are included in the  $\varepsilon$  term where  $\varepsilon = (\pi/P\kappa)^{1/2}$ , where  $P$  is the period  
263 of the heating cycle and  $\kappa$  is the thermal diffusivity of the ground. As mentioned above,  
264 thermal diffusivity can be estimated from two vertically separated temperature measurements  
265 and for Wallingford, utilising the temperatures at 50 and 100 cm depths, the value for  $\kappa$  is  
266  $6.754 \times 10^{-7} \text{ m}^2 \text{ s}^{-1}$  (Busby 2015). The amplitude of the heating cycle at 50 cm depth,  $T_0$ , is  
267 equal to 5.47 °C and the mean value of temperature at 50 cm depth is equal to 11.71 °C (see  
268 Table A2 in the Appendix). The resulting extrapolated temperatures from 0 to 5 m depths are  
269 shown in Figure 4. The phase offset was aligned from the known offset between the 50 and  
270 100 cm depth seasonally fitted temperature curves. It should also be noted that the  
271 extrapolated curve at 1 m depth fits the 100 cm depth seasonally fitted curve to within ±0.1  
272 °C. Hence, at Wallingford, the seasonal range in temperature is 13.3 °C at 0 cm depth, which  
273 is dampened to 4.2 °C at 3 m depth and 1.9 °C at 5 m depth. The time offset in the peaks and  
274 troughs of the seasonal temperature cycle, compared to the temperature at 0 cm depth, is 67  
275 days at 3 m depth and 112 days at 5 m depth. Beardsmore & Cull (2001) define the effective  
276 wavelength ( $z_{wl} = (4\pi P\kappa)^{1/2}$ ) as the depth at which the temperature fluctuation is in phase with  
277 that at 0 cm depth with a temperature perturbation equal to 0.0019 of that at 0 cm depth. This  
278 depth is considered to be the maximum depth to which seasonal temperature fluctuations  
279 need to be considered. At Wallingford, the effective wavelength is 16.4 m with a temperature  
280 perturbation of 0.03 °C.

## 281 **Conclusions**

282 The UK Government is committed to carbon emission reductions and a substantial increase  
283 in heat provided by renewables, including ground source heat (DECC 2013). The EU requires  
284 that Member States shall ensure that by 31 December 2020 all new buildings are nearly zero-  
285 energy buildings and the nearly zero or very low amount of energy required should be  
286 covered to a very significant extent by energy from renewable sources (EU 2010). It is  
287 therefore expected that there will be a substantial increase in the number of ground coupled  
288 heating systems installed in the UK over the next decade. Those planning or designing such  
289 systems require information and tools to assist them. For instance, Abesser et al. (2014) have  
290 produced an on-line tool for an initial assessment of the suitability of a site for open loop  
291 GSHP at the scale of a commercial building. Knowledge of shallow ground temperatures is  
292 also important in contaminated land studies since temperature is an important determinant in  
293 the rate of biodegradation (e.g. Leahy & Colwell 1990; Benoit et al. 2007; Yadav &  
294 Hassanizadeh 2011)

295 The data presented here are primarily intended to assist in the design of very shallow ground  
296 coupled heating systems where the seasonal swing of ground temperatures has to be taken  
297 into consideration. Soil temperatures from 106 Met Office stations have been analysed and  
298 tabulated data have been presented of the mean annual and seasonal temperatures, and the  
299 expected daily minimum and maximum temperatures, within the top one metre of the ground  
300 across the UK. Mean annual soil temperatures are, on average, 1 °C higher than mean annual  
301 air temperatures. Mean annual temperatures at 1 m depth, reduced to sea level, range from  
302 12.7 °C in southern England to 8.8 °C in northern Scotland, with corresponding seasonal  
303 ranges in temperature of 10.3 °C and 7.9 °C, respectively. An average UHI effect at 1 m  
304 depth of 0.55 °C has been observed at localities adjacent to urban green spaces, from which it  
305 can be assumed that the UHI effect will be greater in densely developed city and town  
306 centres.

307 A linear relation has been derived from which the mean annual temperature for any non-  
308 urban UK locality, at 1 m depth, can be calculated. Accurate temperatures to several metres  
309 depth are also sometimes required and this has been demonstrated, on a site specific basis, by  
310 extrapolating the seasonal temperature cycle to depth.

## 311 **Acknowledgements**

312 This paper is published by permission of the Executive Director of the British Geological  
313 Survey (NERC). The UK Met Office is thanked for making available the soil temperature  
314 data held in the Met Office Database – MIDAS and made available through the British  
315 Atmospheric Data Centre (BADC).

## 316 **References**

- 317 ABESSER, C., LEWIS, M. A., MARCHANT, A. P. & HULBERT, A. G. 2014. Mapping suitability  
318 for open-loop ground source heat pump systems: a screening tool for England and  
319 Wales, UK. *Quarterly Journal of Engineering Geology and Hydrogeology*, **47**, 373–  
320 380. <http://dx.doi.org/10.1144/qjegh2014-050>
- 321 ADAMS, W. M., WATTS, G. & MASON, G. 1976. Estimation of thermal diffusivity from field  
322 observations of temperature as a function of time and depth. *American Mineralogist*,  
323 **61**, 560-568.
- 324 AROLA, T. & KORRKA-NIEMI, K. 2014. The effect of urban heat islands on geothermal  
325 potential: examples from Quaternary aquifers in Finland. *Hydrogeology Journal*, **22**,  
326 1953-1967.

- 327 BANKS, D. 2008. An Introduction to Thermogeology: Ground source heating and cooling.  
328 Oxford: Blackwell.
- 329 BANKS, D., GANDY, C. J., YOUNGER, P. L., WITHERS, J. & UNDERWOOD, C. 2009.  
330 Anthropogenic thermogeological ‘anomaly’ in Gateshead, Tyne and Wear, UK.  
331 *Quarterly Journal of Engineering Geology and Hydrogeology*, **42**, 307–312.
- 332 BEARDSMORE, G. R. & CULL, J. R. 2001. *Crustal heat flow: a guide to measurement and*  
333 *modelling*. Cambridge: Cambridge University Press.
- 334 BENOIT, P., PERCEVAL, J., STENRØD, M., MONI, C., EKLO O. M., BARRIUSO, E., SVEISTRUP, T.  
335 & KVÆRNER, J. 2007. Availability and biodegradation of metribuzin in alluvial soils as  
336 affected by temperature and soil properties. *Weed Research*, **47**, 517–526.
- 337 BUSBY, J. 2015. Determination of thermal properties for horizontal ground collector loops.  
338 Proceedings World Geothermal Congress 2015, Melbourne, Australia, 19-25 April  
339 2015.
- 340 BUSBY, J., LEWIS, M., REEVES, H. & LAWLEY, R. 2009. Initial geological considerations before  
341 installing ground source heat pump systems. *Quarterly Journal of Engineering Geology*  
342 *and Hydrogeology*, **42**, 295–306.
- 343 EU. 2010. DIRECTIVE 2010/31/EU OF THE EUROPEAN PARLIAMENT AND OF THE  
344 COUNCIL of 19 May 2010 on the energy performance of buildings (recast). Official  
345 Journal of the European Union, L153/13-35. [http://eur-](http://eur-lex.europa.eu/LexUriServ/LexUriServ.do?uri=OJ:L:2010:153:0013:0035:EN:PDF)  
346 [lex.europa.eu/LexUriServ/LexUriServ.do?uri=OJ:L:2010:153:0013:0035:EN:PDF](http://eur-lex.europa.eu/LexUriServ/LexUriServ.do?uri=OJ:L:2010:153:0013:0035:EN:PDF)
- 347 DECC. 2013. The Future of Heating: Meeting the challenge. Department of Energy and  
348 Climate Change.  
349 [https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/190149/](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/190149/16_04-DECC-The_Future_of_Heating_Accessible-10.pdf)  
350 [16\\_04-DECC-The\\_Future\\_of\\_Heating\\_Accessible-10.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/190149/16_04-DECC-The_Future_of_Heating_Accessible-10.pdf)
- 351 FERGUSON, G. & WOODBURY, A. D. 2004. Subsurface heat flow in an urban environment.  
352 *Journal of Geophysical Research*, **109**, B02402, 9 pp.
- 353 FERGUSON, G. & WOODBURY, A. D. 2007. Urban heat island in the subsurface. *Geophysical*  
354 *Research Letters*, **34**, L23713.
- 355 HEADON, J., BANKS, D., WATERS, A. & ROBINSON, V. K. 2009. Regional distribution of  
356 ground temperature in the Chalk aquifer of London, UK. *Quarterly Journal of*  
357 *Engineering Geology and Hydrogeology*, **42**, 313–323.
- 358 HORTON, R., WIERENGA, P. J., & NIELSEN, D. R. 1983. Evaluation of methods for determining  
359 apparent thermal diffusivity of soil near the surface, *Journal of the American Soil*  
360 *Science Society*, **47**, 23–32.
- 361 ICAO. 1993. International Civil Aviation Organization, *Manual of the ICAO Standard*  
362 *Atmosphere (extended to 80 kilometres (262 500 feet))*, Doc 7488-CD, Third Edition,  
363 1993, ISBN 92-9194-004-6.
- 364 IGSHA. 1996. Closed-loop/Ground-Source Heat Pump Systems: Installation guide.  
365 Oklahoma State University: International Ground Source Heat Pump Association  
366 Publications.
- 367 KAPPELMEYER, O. & HAENEL, R. 1974. Geothermics with special reference to application.  
368 Geoexploration Monographs Series 1 – No 4, Gebruder Borntraeger: Berlin - Stuttgart  
369 238 pp.



- 370 LEAHY, J. G. & COLWELL, R. R. 1990. Microbial Degradation of Hydrocarbons in the  
371 Environment. *Microbiological Reviews*, **54**, 305-315.
- 372 LINACRE, E. & GEERTS, B. 1997. *Climates and Weather Explained*. Routledge, London.
- 373 MAGEE, N., CURTIS, J. & WENDLER, G. 1999. The urban heat island effect at Fairbanks,  
374 Alaska. *Theoretical and Applied Climatology*, **64**, 39-47.
- 375 MENBERG, K., BAYER, P., ZOSEDER, K., RUMOHR, S. & BLUM, P. 2013. Subsurface urban  
376 heat islands in German cities. *Science of the Total Environment*, **442**, 123-133.
- 377 MET OFFICE. 2010. Observations. *National Meteorological Library and Archive Fact Sheet*  
378 *17 – Weather observations over land*,  
379 [www.metoffice.gov.uk/media/pdf/k/5/Fact\\_sheet\\_No.\\_17.pdf](http://www.metoffice.gov.uk/media/pdf/k/5/Fact_sheet_No._17.pdf).
- 380 MIS 3005. 2013. Microgeneration Installation Standard, MIS 3005: Requirements for  
381 contractors undertaking the supply, design, installation, set to work, commissioning and  
382 handover of microgeneration heat pump systems, Issue 4.1,  
383 [www.microgenerationcertification.org](http://www.microgenerationcertification.org).
- 384 OKE, T. R. 1973. City size and the urban heat island *Atmospheric Environment*, **7**, 769-779.
- 385 ORME, M. & ISANSKA-CWIEK, A. 2012. Solar-assisted ground coupling for a naturally  
386 ventilated school building. BSO12, *First Building Simulation and Optimization*  
387 *Conference*, Loughborough, UK, 10-11 September 2012, IBPSA-England, 124-131.
- 388 PERRIER, F., LE MOUËL, J. L., POIRIER, J. P. & SHNIRMAN, M. G. 2005. Long-term climate  
389 change and surface versus underground temperature measurements in Paris.  
390 *International Journal of Climatology*, **25**, 1619-1631.
- 391 PERRY, M. & HOLLIS, D. 2005. The development of a new set of long-term climate averages  
392 for the UK. *International Journal of Climatology*, **25**, 1023-1039.
- 393 PIKE, D., BANKS, D., WATERS, A. & ROBINSON, V. K. 2011. Regional distribution of  
394 temperature in the Chalk of the western London Basin syncline. *Quarterly Journal of*  
395 *Engineering Geology and Hydrogeology*, **46**, 117-125.
- 396 POLLACK, H. N., HUANG, S. P. & SHEN, P. Y. 1998. Climate change record in subsurface  
397 temperatures: a global perspective. *Science*, **282**, 279-281.
- 398 RYBACH, L. & SANNER, B. 2000. Ground-source heat pump systems; the European  
399 experience. *Geo-Heat Center Bulletin*, **21**, 16-26.
- 400 TANIGUCHI, M., UEMURA, T. & JAGO-ON, K. 2007. Combined effects of urbanization and  
401 global warming on subsurface temperature in four Asian cities. *Vadose Zone Journal*,  
402 **6**, 591-596.
- 403 VDI. 2001. Thermal use of the underground: Ground source heat pump systems. Verein  
404 Deutscher Ingenieure. Richtlinien VDI 4640 Blatt2/Part2 , September 2001, Düsseldorf  
405 43 pp.
- 406 YADAV, B. K. & HASSANIZADEH, S. M. 2011. An overview of biodegradation of LNAPLS in  
407 coastal (semi)-arid environment. *Water Air Soil Pollution*, **220**, 225-239.
- 408
- 409 ZHU, K., BLUM, P., FERGUSON, G., BALKE, K-D. & BAYER, P. 2010. The geothermal potential  
410 of urban heat islands. *Environmental Research Letters*, **5**, 044002, 6 pp.
- 411
- 412

1 **Figure and Table captions**

2 Figure 1. Five year temperature record (from the 1<sup>st</sup> January 2000) from the Met Office  
3 weather station at Eastbourne. The black record is the temperature at 30 cm depth and the  
4 grey record from 100 cm depth. The rapidly fluctuating records are the daily measurements  
5 and the smooth records are the best fit through the data of an appropriate periodic function.

6 Figure 2. The locations of the 106 Met Office weather stations from which soil temperature  
7 data have been utilised. The stations are numbered from 1 to 106 based on their northing.  
8 Geographical information for the stations is presented in Table A1 in the Appendix.

9 Figure 3. Plot of the mean annual temperatures at 100 cm depth, for non-urban locations  
10 corrected to sea level, plotted against northing. The best linear fit through the data is shown  
11 by the solid line, which had a coefficient of determination of 0.9.

12 Figure 4. Seasonal soil temperature cycles at the Wallingford Met Office weather station. The  
13 seasonally fitted temperatures at 50 cm depth have been extrapolated to depths 0-5 m based  
14 on the periodic nature of the cycle. Site specific values of thermal diffusivity, mean value of  
15 temperature at 50 cm depth and amplitude of the heating cycle at 50 cm depth are given in the  
16 text.

17 Table 1. Mean annual and seasonal minimum and maximum temperatures at 100 cm depth  
18 reduced to sea level.

19 Table 2. Estimation of the urban heat island (UHI) effect based on comparisons of mean  
20 annual temperatures at 100 cm depth between urban and, near-by, rural locations.  
21 Temperatures are over the same time period for each comparison and the temperature at the  
22 rural location has been corrected for the elevation difference to the urban site using the  
23 Environmental Lapse Rate of 0.65 °C per 100 m.

24 Table 3. Estimation of a seasonal UHI effect based on comparisons of seasonal temperatures  
25 at 100 cm depth between urban and, near-by, rural locations. Temperatures are over the same  
26 time period for each comparison and the temperature at the rural location has been corrected  
27 for the elevation difference to the urban site using the Environmental Lapse Rate of 0.65 °C  
28 per 100 m.

29 Table 4. Comparisons between mean annual air temperatures and mean annual temperatures  
30 at 100 cm depth, calculated over the same time period for each comparison.

31 **Appendix Tables**

32 Table A1. Geographical information for the Met Office weather stations referred to in this  
33 paper. The record number (Rec) orders the stations based on northing and is used as the  
34 station identifier in Figure 2. The unique source identifier (src\_id) is the Met Office station  
35 number. Eastings and northings are British National Grid and elevation is relative to OD  
36 (Ordnance Datum).

37 Table A2. Tabulated results of the mean annual (Mean), seasonal minimum ( $S_{\min}$ ) and  
38 maximum ( $S_{\max}$ ), and daily minimum ( $D_{\min}$ ) and maximum ( $D_{\max}$ ) temperatures for Met  
39 Office weather stations in England. The time period (in complete years) is the time over  
40 which the temperatures were calculated and the depth (in brackets to the right of the time  
41 period) is the depth of the temperature measurements.


42 Table A3. Tabulated results of the mean annual (Mean), seasonal minimum ( $S_{\min}$ ) and  
43 maximum ( $S_{\max}$ ), and daily minimum ( $D_{\min}$ ) and maximum ( $D_{\max}$ ) temperatures for Met  
44 Office weather stations in Scotland. Time period and depth are as described for Table A2.


45 Table A4. Tabulated results of the mean annual (Mean), seasonal minimum ( $S_{\min}$ ) and  
46 maximum ( $S_{\max}$ ), and daily minimum ( $D_{\min}$ ) and maximum ( $D_{\max}$ ) temperatures for Met  
47 Office weather stations in Wales. Time period and depth are as described for Table A2.

48 Table A5. Tabulated results of the mean annual (Mean), seasonal minimum ( $S_{\min}$ ) and  
49 maximum ( $S_{\max}$ ), and daily minimum ( $D_{\min}$ ) and maximum ( $D_{\max}$ ) temperatures for Met  
50 Office weather stations in Northern Island. Time period and depth are as described for Table  
51 A2.


52


53





Temperature (°C)





Met station id		Abbreviated station name	Sea level 100 cm temps. (°C)			
Rec	Src_id		Mean	S <sub>min</sub>	S <sub>max</sub>	
<b>ENGLAND</b>	1	1395	Camborne	12.7	8.0	17.5
	3	1326	Swanage	12.7	8.1	17.3
	4	843	Bournemouth	12.7	7.2	18.3
	5	842	Hurn	11.6	6.5	16.7
	6	808	Eastbourne	12.9	7.8	18.1
	7	16608	Littlehampton	12.7	6.9	18.6
	8	1383	Dunkeswell Aerodrome	12.8	7.5	18.2
	9	865	Butser, Windmill Hill	11.8	6.8	16.8
	10	1346	Chivenor	12.8	7.7	17.8
	12	868	Alice Holt Lodge	12.4	7.3	17.5
	13	760	Wye	12.0	6.7	17.3
	14	1304	Rodney Stoke	12.1	7.0	17.2
	15	719	Wisley	12.2	7.0	17.3
	17	838	Bracknell	12.1	6.9	17.4
	18	830	Reading University	12.2	7.2	17.2
	20	697	St James Park	13.0	7.4	18.7
	22	825	Wallingford	11.9	7.4	16.4
	23	613	Benson	12.0	7.0	17.0
	24	609	Shirburn	12.3	6.6	18.0
	27	606	Oxford	12.4	6.5	18.3
	28	471	Rothamsted	12.0	6.7	17.4
	31	458	Woburn	11.2	6.7	15.7
	32	596	Wellesbourne	11.7	5.6	17.8
	33	454	Cambridge Botanical Gardens	11.7	6.2	17.2
	34	461	Bedford	11.7	6.9	16.4
	35	578	Northampton, Moulton Park	12.4	7.1	17.8
	36	435	Brooms Barn	12.3	6.2	18.4
	37	445	Westleton	11.9	5.2	18.5
	39	595	Church Lawford	12.0	6.1	17.9
	40	24102	Coventry, Coundon	12.0	6.3	17.7
	41	663	Halesowen	11.7	6.9	16.5
	42	19187	Coleshill	11.6	6.3	17.0
	43	413	Santon Downham	11.6	6.0	17.3
	44	638	Preston Montford	11.6	5.8	17.5
	47	392	Kirton Horticulture	10.8	5.5	16.1
	48	421	Weybourne	11.3	5.4	17.3
	49	622	Keele	11.6	6.6	16.5
	51	539	Buxton	11.8	6.2	17.4
	52	525	Sheffield	12.0	6.4	17.6
	53	19204	Gringley-on-the-hill	11.2	6.0	16.4
	55	516	Bradford	11.7	6.4	17.0
	56	535	Cawood	11.1	4.7	17.5
	57	1112	Myerscough	11.9	5.7	18.0
	59	1105	Hazelrigg	11.1	6.6	15.7
	62	1083	Shap	10.6	5.5	15.8
	65	1074	Warcop Range	10.8	5.8	15.9
	66	1060	Keswick	10.8	5.7	15.9
	67	17182	Copley	11.2	6.1	16.3
	71	326	Durham	11.5	6.1	16.9
	72	1066	Drumburgh	10.8	6.1	15.5
	73	1070	Carlisle	10.7	5.5	15.9
<b>SCOTLAND</b>	77	1023	Eskdalemuir	11.3	6.6	16.0
	78	968	Paisley	11.3	6.4	16.1
	79	24125	Glasgow Bishopton	10.8	5.8	15.8
	80	19260	Edinburgh Gogarbank	10.3	5.5	15.1



83	212	Strathallan airfield	9.9	4.5	15.4	
84	235	Leuchars	9.9	5.1	14.8	
85	181	Mylnefield	9.9	5.5	14.3	
86	214	Faskally	10.4	4.6	16.2	
87	177	Inverbervie No 2	10.5	5.8	15.2	
88	17310	Fettercairn, Glensaugh No 2	9.8	4.7	14.8	
89	105	Tulloch Bridge	10.5	4.7	16.2	
90	147	Braemar	10.4	5.3	15.5	
91	150	Aboyne No 2	9.9	4.6	15.2	
92	160	Craibstone	9.8	4.7	14.9	
93	161	Dyce	9.7	5.2	14.2	
94	113	Aviemore	9.8	4.5	15.2	
95	19172	Skye: Lusa	9.7	5.2	14.2	
96	18903	South Uist range	10.0	5.6	14.3	
97	132	Kinloss	9.3	4.8	13.9	
98	79	Tain Range	9.0	4.7	13.3	
99	52	Aultbea No 2	9.9	5.0	14.8	
100	54	Stornoway Airport	9.6	5.2	14.1	
101	44	Altnaharra No 2	9.4	4.7	14.1	
103	23	Kirkwall	9.1	4.9	13.4	
104	3	Fair Isle	9.2	5.8	12.7	
105	9	Lerwick	8.8	5.5	12.1	
<b>WALES</b>	21	1256	Penmaen	12.9	7.5	18.2
	30	1223	Whitechurch	12.1	8.0	16.2
	38	1209	Trawsgoed	12.1	7.3	16.9
	45	1161	Aberdaron	12.3	7.6	17.0
	46	1180	Bala	12.0	6.5	17.6
	50	1154	Loggerheads	11.8	6.7	16.9
<b>N. IRELAND</b>	60	1502	Murlough	11.0	6.3	15.7
	61	1509	Magherally	11.2	7.0	15.5
	63	1568	St Angelo	11.3	6.0	16.7
	64	1532	Annaghmore	11.4	7.3	15.5
	68	1517	Ballywatticock	10.8	6.7	15.0
	70	1523	Helens Bay	10.7	6.3	15.1
	76	1437	Coleraine University	10.5	6.5	14.5

Table 1

Table 2

Urban mean temp. (°C)		Rural mean temp. (°C)		Elevation diff. (m)	Elevation corrected rural mean temp. (°C)	UHI effect at urban location (°C)
Bournemouth	12.5	Hurn	11.6	17	11.5	1.0
Reading	11.7	Bracknell	11.7	-8	11.7	0.0
Oxford	12.0	Benson	11.6	-4	11.6	0.4
Cambridge	11.6	Brooms Barn	11.8	-63	12.2	-0.6
Northampton	11.6	Bedford	11.1	42	10.8	0.8
Coventry	11.2	Coleshill	11.0	12	10.9	0.3
Sheffield	11.1	Gringley-on-the-Hill	10.8	63	10.4	0.7
Bradford	10.8	Cawood	11.2	128	10.4	0.4
Durham	10.8	Copley	9.6	-151	10.5	0.3
Paisley	11.1	Glasgow Bishopton	10.4	-27	10.6	0.5

Table 3

Urban seasonal temp. (°C)			Rural corrected seasonal temp. (°C)			Seasonal UHI effect at urban location (°C)	
Met station	S <sub>min</sub>	S <sub>max</sub>	Met station	S <sub>min</sub>	S <sub>max</sub>	S <sub>min</sub>	S <sub>max</sub>
Bournemouth	7.0	18.1	Hurn	6.3	16.6	0.7	1.5
Reading	6.8	16.8	Bracknell	6.4	17.0	0.4	-0.2
Oxford	6.1	17.9	Benson	6.6	16.6	-0.5	1.3
Cambridge	6.1	17.1	Brooms Barn	6.1	18.3	0.0	-1.2
Northampton	6.3	17.0	Bedford	6.1	15.6	0.2	1.4
Coventry	5.5	17.0	Coleshill	5.6	16.2	-0.1	0.8
Sheffield	5.5	16.8	Gringley-on-the-Hill	5.2	15.6	0.3	1.2
Bradford	5.5	16.1	Cawood	4.3	16.5	1.2	-0.4
Durham	5.4	16.2	Copley	5.4	15.7	0.0	0.5
Paisley	6.2	15.9	Glasgow Bishopton	5.6	15.6	0.6	0.3

Table 4

Met Office station	Mean annual temp. at 100 cm depth (°C)	Mean annual air temp. (°C)	Difference of soil to air temp. (°C)
Camborne	12.2	11.1	1.1
Hurn	11.6	10.7	0.9
Eastbourne	12.9	11.7	1.2
Wallingford	11.6	10.9	0.7
Oxford	12.0	11.1	0.9
Cambridge	11.6	10.8	0.8
Sheffield	11.1	10.6	0.5
Durham	10.8	9.6	1.2
Eskdalemuir	9.8	7.8	2.0
Braemar	8.2	7.3	0.9
Stornoway airport	9.5	9.0	0.5
Lerwick	8.3	7.8	0.5

Rec	src_id	Met Office Weather Station name	Easting (m)	Northing (m)	Elevation (m)
1	1395	Camborne	162700	40700	87
2	877	Isle of Wight, Ventnor	455700	77300	60
3	1326	Swanage	403016	79332	10
4	843	Bournemouth	412500	92772	27
5	842	Hurn	411644	97778	10
6	808	Eastbourne	561100	98000	7
7	16608	Littlehampton, Toddington Lane	503700	104100	3
8	1383	Dunkeswell Aerodrome	312815	107480	252
9	865	Butser, Windmill Hill	472000	116500	92
10	1346	Chivenor	249600	134400	6
11	7786	Boyton	395209	140259	87
12	868	Alice Holt Lodge	480500	142700	115
13	760	Wye	605890	147010	56
14	1304	Rodney Stoke	348849	150155	40
15	719	Wisley	506300	157900	38
16	1311	Bath	375131	163725	114
17	838	Bracknell	484600	166400	74
18	830	Reading University, Whiteknights No 3	473900	171900	66
19	723	Kew	518680	177380	6
20	697	St James' Park, London	529800	180000	5
21	1256	Penmaen	253100	188800	87
22	825	Wallingford	461800	189800	48
23	613	Benson	462500	191669	67
24	609	Shirburn	469500	197100	108
25	469	Aldenham School	515741	197284	91
26	688	Cirencester	400300	201100	133
27	606	Oxford	450900	207200	63
28	471	Rothamsted	513156	213280	128
29	1231	Llandeilo	259700	219900	80
30	1223	Whitechurch	216200	235600	129
31	458	Woburn	496400	236000	89
32	596	Wellesbourne	427100	256500	47
33	454	Cambridge Botanical Gardens	545600	257200	12
34	461	Bedford	504900	259700	85
35	578	Northampton, Moulton Park	476400	264500	127
36	435	Brooms Barn	575300	265600	75
37	445	Westleton	647300	267200	10
38	1209	Trawsgoed	267395	273590	63
39	595	Church Lawford	445600	273600	107
40	24102	Coventry, Coundon	431600	280800	119
41	663	Halesowen	394900	282200	153
42	19187	Coleshill	421090	286940	96
43	413	Santon Downham	581600	287900	6
44	638	Preston Montford	343200	314400	71
45	1161	Aberdaron	215200	324800	95
46	1180	Bala	293500	335600	163
47	392	Kirton Horticulture	529920	339450	4
48	421	Weybourne	609900	343700	21
49	622	Keele	381900	344600	179
50	1154	Loggerheads, Colomendy Centre	320030	362160	210
51	539	Buxton	405800	373400	307
52	525	Sheffield	433930	387280	131
53	19204	Gringley-on-the-hill	474260	390500	68
54	369	Hull	508350	430130	2
55	516	Bradford	414900	435200	134

56	535	Cawood	456100	437200	6
57	1112	Myerscough	349500	440000	14
58	370	Leconfield	502545	443169	7
59	1105	Hazelrigg	349300	457820	95
60	1502	Murlough	150486	490209	12
61	1509	Magherally	127475	504236	97
62	1083	Shap	355700	512000	255
63	1568	St Angelo	33740	514703	47
64	1532	Annaghmore	101838	516887	27
65	1074	Warcop Range	373300	519700	227
66	1060	Keswick	325300	524900	81
67	17182	Copley	408500	525400	253
68	1517	Ballywatticock	163835	525962	6
69	1073	Newton Rigg	349300	530800	169
70	1523	Helens Bay	158462	536950	43
71	326	Durham	426700	541500	102
72	1066	Drumburgh	325900	560200	7
73	1070	Carlisle	338300	560300	28
74	24790	Drumlamford House	228800	576900	132
75	310	Morpeth, Cockle Park	420000	591200	95
76	1437	Coleraine University	102081	594462	23
77	1023	Eskdalemuir	323500	602600	242
78	968	Paisley	247895	664032	32
79	24125	Glasgow Bishopton	241788	671073	59
80	19260	Edinburgh Gogarbank	316100	671400	57
81	247	Edinburgh, East Craigs	318500	673500	61
82	253	Edinburgh Botanic Gardens	324500	675500	26
83	212	Strathallan airfield	293100	716200	35
84	235	Leuchars	346800	720900	10
85	181	Mylnefield	333900	730100	31
86	214	Faskally	291800	759900	94
87	177	Inverbervie No 2	383884	773425	134
88	17310	Fettercairn, Glensaugh No 2	366900	778200	171
89	105	Tulloch Bridge	235030	778298	237
90	147	Braemar	315200	791400	339
91	150	Aboyne No 2	349300	798700	140
92	160	Craibstone	387100	810700	102
93	161	Dyce	387810	812800	65
94	113	Aviemore	289652	814315	228
95	19172	Skye: Lusa	170593	824888	18
96	18903	South Uist range	76312	842502	4
97	132	Kinloss	306774	862804	5
98	79	Tain Range	283272	882720	4
99	52	Aultbea No 2	184575	891274	11
100	54	Stornoway Airport	146443	933104	15
101	44	Altnaharra No 2	256908	935830	81
102	32	Wick Airport	336490	952230	36
103	23	Kirkwall	348236	1007709	26
104	3	Fair Isle	421046	1071185	57
105	9	Lerwick	445392	1139664	82
106	12	Baltasound No 2	462488	1207786	15

Appendix Table A1

Rec	Src_id	Abbreviated station name	Time period & Depth (cm)	Mean (°C)	S <sub>min</sub> (°C)	S <sub>max</sub> (°C)	D <sub>min</sub> (°C)	D <sub>max</sub> (°C)
1	1395	Camborne	2000-2010 (30)	12.1	6.7	17.5	3.0	20.0
			2000-2010 (100)	12.2	7.4	16.9	5.5	18.3
2	877	Isle of Wight	2000-2003 (30)	12.7	5.9	19.4	3.0	22.9
3	1326	Swanage	2000-2003 (100)	12.6	8.1	17.2	7.2	18.7
4	843	Bournemouth	2000-2003 (30)	12.4	5.6	19.3	2.5	22.8
			2000-2003 (100)	12.5	7.0	18.1	5.7	20.0
5	842	Hurn	2000-2010 (30)	11.9	5.1	18.7	1.6	22.8
			2000-2010 (100)	11.6	6.3	16.9	4.1	19.2
6	808	Eastbourne	2000-2004 (30)	12.5	6.0	19.1	2.7	22.8
			2000-2004 (100)	12.9	7.8	18.0	6.7	19.7
7	16608	Littlehampton	2000-2002 (50)	12.6	6	19.2	3.3	21.7
			2000-2002 (100)	12.7	6.9	18.6	5.1	20.3
8	1383	Dunkeswell	2001-2010 (30)	11.5	4.5	18.5	-0.1	21.9
			2001-2010 (100)	11.2	5.9	16.5	2.2	18.8
9	865	Butser	2000-2004 (50)	11.4	5.4	17.4	3	19.4
			2000-2004 (100)	11.2	6.2	16.2	4.5	17.0
10	1346	Chivenor	2001-2010 (30)	12.4	6.3	18.5	2.0	21.2
			2001-2010 (100)	12.7	7.7	17.8	5.8	19.5
11	7786	Boyton	2000-2004 (30)	11.4	5.4	17.3	2.6	20.8
12	868	Alice Holt Lodge	2000-2006 (50)	11.7	5.4	18.1	3.2	20.0
			2000-2006 (100)	11.7	6.6	16.8	5.5	17.5
13	760	Wye	2000-2004 (50)	11.7	5.5	17.8	3	20.7
			2000-2004 (100)	11.6	6.3	16.9	5.2	18.9
14	1304	Rodney Stoke	2000-2004 (50)	12.0	5.8	18.3	4.0	21.5
			2000-2004 (100)	11.9	6.8	17.0	6.0	18.5
15	719	Wisley	2000-2000 (50)	12.0	5.9	18.2	3.3	19.3
			2000-2000 (100)	11.9	6.8	17.1	5.6	17.7
16	1311	Bath	2000-2004 (30)	12.2	5.6	18.9	3.0	23.0
17	838	Bracknell	2000-2002 (100)	11.7	6.4	16.9	4.8	17.9
18	830	Reading Univ.	2000-2006 (50)	11.8	5.9	17.7	3.4	20.5
			2000-2006 (100)	11.8	6.8	16.8	5.6	18.2
19	723	Kew	2000-2004 (30)	11.9	4.7	19.0	2.1	23.6
20	697	St James Park	2000-2004 (30)	13.6	6.5	20.7	4.3	24.0
			2000-2004 (100)	13.0	7.4	18.6	6.3	21.6
22	825	Wallingford	2000-2006 (50)	11.7	6.2	17.2	4.0	20.2
			2000-2006 (100)	11.6	7.1	16.1	6.0	17.8
23	613	Benson	2007-2008 (30)	11.4	5.5	17.4	3.7	18.9
			2007-2008 (100)	11.6	6.6	16.6	5.9	17.4
24	609	Shirburn	2000-2004 (30)	11.4	4.4	18.5	1.5	21.7
			2000-2004 (100)	11.6	5.9	17.3	4.7	19.1
25	469	Aldenham School	2000-2004 (30)	10.8	4.2	17.4	1.5	20.5
26	688	Cirencester	2000-2004 (30)	11.1	4.2	17.9	0.2	22.0
			2000-2004 (50)	11.3	4.8	17.9	2.6	21.3
27	606	Oxford	2000-2004 (30)	11.8	4.4	19.3	4.3	24.0
			2000-2004 (100)	12.0	6.1	17.9	6.3	21.6
28	471	Rothamsted	2001-2010 (30)	11.1	4.1	18.0	1.8	21.7
			2001-2010 (100)	11.2	5.8	16.6	4.2	18.0
31	458	Woburn	2001-2003 (30)	10.8	4.6	17.0	2.0	19.3
			2001-2003 (100)	10.6	6.1	15.1	5.2	16.0
32	596	Wellesbourne	2000-2004 (50)	11.3	4.5	18.1	2.2	21.3
			2000-2004 (100)	11.4	5.3	17.5	3.8	20.0
33	454	Cambridge	2000-2004 (30)	11.4	4.4	18.4	1.8	21.8
			2000-2004 (100)	11.6	6.1	17.1	4.9	18.9
34	461	Bedford	2000-2008 (30)	11.3	5.0	17.6	2.9	21.3
			2000-2008 (100)	11.1	6.4	15.9	5.3	17.7
35	578	Northampton	2000-2006 (50)	11.8	5.2	18.5	3.5	21.2
			2000-2006 (100)	11.6	6.3	17.0	5.1	18.8
36	435	Brooms Barn	2000-2006 (50)	11.8	4.8	18.9	2.7	21.3

			2000-2006 (100)	11.8	5.7	17.9	4.7	19.7
37	445	Westleton	2000-2004 (50)	11.8	4.3	19.2	1.7	23.0
			2000-2004 (100)	11.8	5.1	18.5	3.7	21.0
39	595	Church Lawford	2000-2010 (30)	11.3	4.5	18.1	2.0	21.5
			2000-2010 (100)	11.3	5.4	17.2	3.4	19.4
40	24102	Coventry	2000-2010 (30)	11.0	3.9	18.1	1.4	23.1
			2000-2010 (100)	11.2	5.5	17.0	4.4	19.4
41	663	Halesowen	2000-2003 (50)	10.7	4.8	16.7	3.2	19.0
			2000-2003 (100)	10.7	6.0	15.5	5.0	17.0
42	19187	Coleshill	2000-2010 (30)	11.1	4.7	17.4	2.4	21.1
			2000-2010 (100)	11.0	5.7	16.3	4.3	18.5
43	413	Santon Downham	2000-2004 (30)	11.4	4.3	18.4	1.8	21.6
			2000-2004 (100)	11.6	5.9	17.3	4.7	19.1
44	638	Preston Montford	2001-2006 (30)	11.1	4.2	18.0	1.2	21.3
			2001-2006 (100)	11.2	5.3	17.0	3.5	18.8
47	392	Kirton Horticulture	2000-2004 (50)	10.9	4.6	17.2	2.8	21.1
			2000-2004 (100)	10.8	5.5	16.1	4.6	18.4
48	421	Weybourne	2000-2003 (30)	10.8	3.7	17.9	-1.5	21.4
			2000-2003 (100)	11.2	5.2	17.1	3.8	19.4
49	622	Keele	2001-2005 (50)	10.6	4.5	16.6	3.0	18.4
			2001-2005 (100)	10.4	5.5	15.3	4.8	16.3
51	539	Buxton	2000-2006 (50)	10.0	3.4	16.6	1.5	19.7
			2000-2006 (100)	9.8	4.2	15.4	2.9	17.9
52	525	Sheffield	2002-2004 (30)	11.0	4.1	18.0	2.1	20.3
			2002-2004 (100)	11.1	5.5	16.8	4.4	18.1
53	19204	Gringley-on-the-hill	2002-2004 (30)	10.8	4.6	17.0	2.1	19.5
			2002-2004 (100)	10.8	5.6	16.0	4.4	17.2
54	369	Hull	2008-2009 (30)	10.8	3.6	18.1	1.0	20.0
55	516	Bradford	2004-2004 (30)	10.6	4.2	17.0	2.9	18.6
			2004-2004 (100)	10.8	5.5	16.1	5.1	17.0
56	535	Cawood	2001-2004 (50)	11.0	3.8	18.2	1.4	20.9
			2001-2004 (100)	11.0	4.6	17.4	3.3	19.5
57	1112	Myerscough	2001-2004 (50)	11.9	4.6	19.2	2.5	21.0
			2001-2004 (100)	11.8	5.7	17.9	4.7	19.1
58	370	Leconfield	2008-2009 (30)	10.8	4.2	17.5	2.1	19.6
59	1105	Hazelrigg	2000-2006 (50)	10.4	4.8	16.0	2.2	18.5
			2000-2006 (100)	10.5	6.0	15.1	4.3	16.5
62	1083	Shap	2005-2010 (30)	9.2	2.6	15.7	1.1	17.5
			2005-2010 (100)	9.0	3.8	14.1	2.7	14.9
65	1074	Warcop Range	2000-2010 (30)	9.5	3.4	15.6	1.2	18.0
			2000-2010 (100)	9.4	4.3	14.4	1.5	16.3
66	1060	Keswick	2000-2001 (30)	11.0	4.1	17.9	2.0	19.5
			2000-2001 (100)	10.3	5.2	15.4	4.5	16.3
67	17182	Copley	2000-2004 (30)	9.7	3.2	16.1	1.9	19.2
			2000-2004 (100)	9.6	4.4	14.7	3.4	16.5
69	1073	Newton Rigg	2000-2006 (30)	10.0	3.4	16.7	0.9	20.4
			2000-2006 (50)	10.2	3.9	16.5	1.8	20.0
71	326	Durham	2000-2004 (30)	10.4	3.5	17.4	1.4	20.3
			2000-2004 (100)	10.8	5.4	16.2	4.7	17.5
72	1066	Drumburgh	2006-2010 (100)	10.8	6.1	15.5	4.9	15.9
73	1070	Carlisle	2006-2010 (100)	10.5	5.3	15.8	3.9	17.5
75	310	Morpeth	2001-2006 (30)	9.51	3.4	15.6	1.4	18.4
			2001-2006 (50)	9.6	3.9	15.3	1.9	17.8

Appendix Table A2



Rec	Src_id	Abbreviated station name	Time period & Depth (cm)	Mean (°C)	S <sub>min</sub> (°C)	S <sub>max</sub> (°C)	D <sub>min</sub> (°C)	D <sub>max</sub> (°C)
74	24790	Drumlamford House	2000-2004 (30)	9.9	4.2	15.7	2.1	18.4
77	1023	Eskdalemuir	2000-2010 (30)	9.9	3.9	15.9	2.3	18.0
			2000-2010 (100)	9.8	5.0	14.5	3.7	15.9
78	968	Paisley	2000-2007 (50)	11.0	4.9	17.0	2.8	19.1
			2000-2007 (100)	11.1	6.2	15.9	5.0	18.0
79	24125	Glasgow, Bishopston	2000-2007 (30)	10.5	4.0	17.1	1.4	19.9
			2000-2007 (100)	10.4	5.5	15.4	4.1	16.7
80	19260	Edinburgh, Gogarbank	2000-2004 (30)	10.1	3.9	16.2	2.0	18.5
			2000-2004 (100)	9.9	5.1	14.7	4.0	15.8
81	247	Edinburgh, East Craigs	2000-2004 (30)	9.7	3.3	16.2	0.7	19.1
			2000-2004 (50)	10.0	4.0	15.9	2.0	18.2
82	253	Edinburgh, Botanic Gardens	2000-2010 (30)	9.8	3.5	16.2	0.9	20.2
83	212	Strathallan airfield	2000-2010 (30)	10.0	3.4	16.7	0.8	19.6
			2000-2010 (100)	9.7	4.2	15.1	2.4	16.5
84	235	Leuchars	2002-2010 (30)	9.8	4.1	15.5	1.4	17.8
			2002-2010 (100)	9.9	5.0	14.7	3.4	16.1
85	181	Mylnefield	2004-2010 (30)	9.6	3.0	16.2	0.0	19.3
			2004-2010 (100)	9.7	5.3	14.1	3.7	15.5
86	214	Faskally	2000-2009 (30)	9.8	2.1	17.5	0.5	20.6
			2000-2009 (100)	9.8	4.0	15.5	2.9	17.0
87	177	Inverbervie No 2	2003-2009 (30)	9.5	3.6	15.5	1.4	18.4
			2003-2009 (100)	9.6	4.9	14.3	3.7	15.4
88	17310	Fettercairn, Glensaugh No 2	2000-2004 (30)	8.7	1.9	15.4	0.5	17.9
			2000-2004 (100)	8.6	3.6	13.7	1.5	14.9
89	105	Tulloch Bridge	2001-2010 (30)	9.1	2.3	15.9	0.8	19.0
			2001-2010 (100)	8.9	3.1	14.7	1.8	16.4
90	147	Braemar	2000-2004 (50)	8.2	2.3	14.1	1.3	15.9
			2000-2004 (100)	8.2	3.1	13.3	2.2	14.6
91	150	Aboyne No 2	2002-2008 (30)	9.2	2.7	15.7	1.8	17.7
			2002-2008 (100)	9.0	3.7	14.3	3.1	15.8
92	160	Craibstone	2000-2004 (30)	9.1	2.9	15.4	1.4	17.3
			2000-2004 (100)	9.1	4.0	14.2	3.0	15.4
93	161	Dyce	2000-2010 (30)	9.3	3.4	15.3	1.6	18.4
			2000-2010 (100)	9.3	4.7	13.8	3.4	14.8
94	113	Aviemore	2000-2010 (30)	8.4	1.7	15.2	0.3	17.5
			2000-2010 (100)	8.3	3.0	13.7	1.2	14.7
95	19172	Skye	2000-2010 (30)	9.8	4.0	15.6	1.4	18.5
			2000-2010 (100)	9.6	5.1	14.1	3.5	15.7
96	18903	South Uist range	2001-2006 (30)	10.1	4.7	15.4	2.0	18.4
			2001-2006 (100)	10.0	5.6	14.3	3.9	16.1
97	132	Kinloss	2000-2010 (30)	9.5	3.7	15.3	0.9	17.6
			2000-2010 (100)	9.3	4.8	13.8	2.6	15.0
98	79	Tain Range	2000-2005 (30)	9.1	3.4	14.7	0.9	16.4
			2000-2005 (100)	9.0	4.7	13.3	2.8	14.3
99	52	Aultbea No 2	2000-2010 (30)	9.8	3.4	16.1	0.0	19.7
			2000-2010 (100)	9.9	5.0	14.7	3.4	16.6
100	54	Stornoway Airport	2004-2010 (30)	9.7	4.2	15.2	1.5	18.0
			2004-2010 (100)	9.5	5.1	14.0	3.7	14.7
101	44	Altnaharra No 2	2000-2010 (30)	8.9	3.0	14.8	1.1	18.5
			2000-2010 (100)	8.9	4.2	13.6	2.9	15.6
102	32	Wick Airport	2002-2010 (30)	8.4	3.3	13.4	1.5	16.5
103	23	Kirkwall	2003-2010 (30)	9.0	3.5	14.5	1.7	17.6
			2003-2010 (100)	9.0	4.7	13.3	3.6	14.7
104	3	Fair Isle	2000-2010 (30)	9.0	4.5	13.4	2.7	16.3
			2000-2010 (100)	8.9	5.4	12.4	4.0	13.4
105	9	Lerwick	2000-2010 (30)	8.4	3.2	13.6	1.3	16.9
			2000-2010 (100)	8.3	5.0	11.6	4.0	13.1
106	12	Baltasound No 2	2002-2009 (30)	8.6	3.1	14.1	1.8	18.0

Appendix Table A3

Appendix Table A4

Rec	Src_id	Abbreviated station name	Time period & Depth (cm)	Mean (°C)	S <sub>min</sub> (°C)	S <sub>max</sub> (°C)	D <sub>min</sub> (°C)	D <sub>max</sub> (°C)
21	1256	Penmaen	2000-2004 (50)	12.3	6.4	18.1	4.7	19.9
			2000-2004 (100)	12.3	7.0	17.6	5.6	18.9
29	1231	Llandeilo	2000-2004 (30)	11.4	5.7	17.1	3.2	19.5
30	1223	Whitechurch	2002-2004 (50)	11.5	6.2	16.8	3.6	17.8
			2002-2004 (100)	11.2	7.2	15.3	5.6	16.1
38	1209	Trawsgoed	2000-2004 (30)	11.8	5.7	18.0	2.7	20.5
			2000-2004 (100)	11.7	6.9	16.5	5.8	17.5
45	1161	Aberdaron	2000-2007 (30)	11.7	6.1	17.2	3.4	19.4
			2000-2007 (100)	11.7	7.0	16.4	5.5	17.5
46	1180	Bala	2000-2001 (50)	11.1	4.9	17.2	2.4	18.1
			2000-2001 (100)	11.0	5.5	16.5	3.3	16.8
50	1154	Loggerheads	2000-2003 (50)	10.3	4.4	16.2	2.5	17.9
			2000-2003 (100)	10.4	5.4	15.5	4.0	17.0

Appendix Table A5

<b>Rec</b>	<b>Src_id</b>	<b>Abbreviated station name</b>	<b>Time period &amp; Depth (cm)</b>	<b>Mean (°C)</b>	<b>S<sub>min</sub> (°C)</b>	<b>S<sub>max</sub> (°C)</b>	<b>D<sub>min</sub> (°C)</b>	<b>D<sub>max</sub> (°C)</b>
60	1502	Murlough	2002-2005 (50)	10.9	5.1	16.7	3.3	18.8
			2002-2005 (100)	10.9	6.2	15.6	5.3	16.8
61	1509	Magherally	2000-2004 (50)	10.5	5.0	16.0	3.3	17.9
			2000-2004 (100)	10.6	6.3	14.9	5.3	15.9
63	1568	St Angelo	2002-2010 (30)	10.8	4.1	17.5	1.1	20.5
			2002-2010 (100)	11.0	5.7	16.4	3.8	17.4
64	1532	Annaghmore	2000-2004 (50)	11.2	6.1	16.3	4.4	18.2
			2000-2004 (100)	11.2	7.2	15.3	6.0	16.5
68	1517	Ballywatticock	2000-2004 (50)	10.9	5.5	16.2	3.5	18.5
			2000-2004 (100)	10.8	6.6	15.0	5.2	16.1
70	1523	Helens Bay	2000-2001 (50)	10.7	5.2	16.2	3.3	17.2
			2000-2001 (100)	10.4	6.1	14.8	4.8	15.0
76	1437	Coleraine University	2000-2000 (30)	10.4	4.8	15.9	3.1	17.8
			2000-2000 (100)	10.3	6.4	14.3	6.6	15.0